

December 8, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Mildred Tart
1010 Wise Road
Dunn NC 28334

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2111-0004

Ms. Tart:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Lot not ready. Corner property irons were not located and accessible. Property line shall be based off survey irons. Incorrect site plan setbacks. DWMH closer than front setback (revision required). No driveway on site plan (revision required).**

Only area large enough for septic area is heavily wooded with overgrowth. Land clearing shall be required to verify septic placement and permits. Advised to have property reviewed by a soil scientist prior to proceeding with clearing/surveying. No permit can be guaranteed due to complex soils.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting

strong roots • new growth