

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT


Name: (owner) Leon Anderson  New Installation  Septic Tank  
Property Location: SR# 1415  Repairs  Nitrification Line  
Subdivision Woodland Ridge Lot # 16  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: Odell Johnson Registration # 78  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50 ft. +

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 20-28 in.  
French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 08519

Date: 09-28-94  
Inspected by: J. H. Gyal R.S.  
Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) LEON ANDERSON  New Installation  Septic Tank  
 Property Location: SR# 1415 401 N  Repairs  Nitrification Line  
T/L 1415 T/R SUBD  
 Subdivision WOODLAND RIDGE Lot # 16  
 Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Number of Bedrooms Proposed: 3 Lot Size: \_\_\_\_\_  
 Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community COUNTY  
 Distance From Well: \_\_\_\_\_ ft.


Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of 2 exact length 150 width of 3 depth of 28 in.  
 ditches of each ditch ft. ditches ft. ditches in.  
 French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 1-29-94  
 Signed: Ron Dudley R.S.  
 Environmental Health Specialist

VOID AFTER 5 YEARS



360 GAL. FLOW RATE /  
 .4 APPLICATION  
 900 sq. ft.