

HTE # 02-5-3993R

OPERATIONS PERMIT

Name: (owner) Michael Anderson Homes Inc New Installation Septic Tank Repair

Property Location: SR# 1443 Nitrification Line Expansion

Subdivision Victoria H. 115th 2 Lot # 219 Tax ID # _____ Quadrant # _____

Contractor: Jason Matthews Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 3 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 36 in.

French Drain Required: _____ Linear feet

Date: 10/26/2005

PERMIT NO. 22161

Inspected by: Bryan McSwain



HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

22161

HTE 02-5-39937

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Michael Anderson Homes Inc
Property Location: SR# 1443 LAFAYETTE RD

New Installation checked
Septic Tank checked
Repairs unchecked
Nitrification Line checked

Subdivision Vic Hells Ph 2 Lot # 219

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 Lot Size: 33,122 sq ft

Basement with Plumbing: unchecked Garage: checked

Water Supply: unchecked Well checked Public unchecked Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: unchecked Conventional unchecked Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 175 ft. width of ditches 3 ft. depth of ditches 36 in.

French Drain Required: - Linear feet

Date: 7-19-05

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhart Environmental Health Specialist

Contractor to meet on site prior to installation.
Construction

