



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

2/10/2022

**SUBJECT: BRES2111-0049**  
**BUILDING RESIDENTIAL**

To: Alexis Collins

Here are the results of all Inspections located at **4164 NC 87 N:**

Inspection Type: FOOTING  
Scheduled Date/Time: 12/14/2021  
Completed Date/Time: 12/14/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 12/14/2021  
Completed Date/Time: 12/14/2021  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 4164 NC 87 N SANFORD 27332

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 12/22/2021  
Completed Date/Time: 12/22/2021  
Inspector: Steven Gazlay  
Result: CANCELLED  
Remarks:  
Notes: lock box code 0227

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 1/10/2022  
Completed Date/Time: 1/10/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ZONING  
Scheduled Date/Time: 2/1/2022  
Completed Date/Time: 2/1/2022 10:30 AM  
Inspector: Kyle Holder  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 2/3/2022  
Completed Date/Time: 2/3/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 2/3/2022  
Completed Date/Time: 2/3/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time: 2/3/2022  
Completed Date/Time: 2/3/2022  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes:

lock box code 0227  
Sewer clean out required within 5 foot of house. Sewer must have 3" minimum soil over.  
Grade around house. Missing breaker/exterior service disconnect for hvac.

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time: 2/10/2022  
Completed Date/Time: 2/10/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

