



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

2/9/2022

SUBJECT: BRES2111-0049
BUILDING RESIDENTIAL

To: Alexis Collins

Here are the results of all Inspections located at **4164 NC 87 N:**

Inspection Type: FOOTING
Scheduled Date/Time: 12/14/2021
Completed Date/Time: 12/14/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 12/14/2021
Completed Date/Time: 12/14/2021
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 4164 NC 87 N SANFORD 27332

Inspection Type: MH FOUND/MARRIAGE WALL
Scheduled Date/Time: 12/22/2021
Completed Date/Time: 12/22/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks:
Notes: lock box code 0227

Inspection Type: MH FOUND/MARRIAGE WALL
Scheduled Date/Time: 1/10/2022
Completed Date/Time: 1/10/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ZONING
Scheduled Date/Time: 2/1/2022
Completed Date/Time: 2/1/2022 10:30 AM
Inspector: Kyle Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 2/3/2022
Completed Date/Time: 2/3/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 2/3/2022
Completed Date/Time: 2/3/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: MFH FINAL**
Scheduled Date/Time: 2/3/2022
Completed Date/Time: 2/3/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes:

lock box code 0227
Sewer clean out required within 5 foot of house. Sewer must have 3" minimum soil over.
Grade around house. Missing breaker/exterior service disconnect for hvac.

Inspection Type: MFH FINAL**
Scheduled Date/Time: 2/10/2022
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

