Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 95 Dragon fly In (NC 27W) ISSUED TO: Daniel Campbell SUBDIVISION REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 28' x 48' DWMH Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: 6 Basement Yes May be required based on final location and elevations of facilities X No Pump Required: Yes Type of Water Supply: Community Public Well Distance from well ______feet X Five years Permit valid for: ■ No expiration Permit conditions: Authorized State Agent:: The issuance of this permit by the Halth Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout, ISSUED TO: Daniel Campbell PROPERTY LOCATION: 95 Dragon Fly Ln (NC 27W) LOT # SUBDIVISION Facility Type: 28' x 48' DWMH Expansion Basement? Yes No Basement Fixtures? Yes X No Type of Wastewater System** 25% reduction (Initial) Wastewater Flow: 360 GPD (See note below, if applicable) 25% reduction Installation Requirements/Conditions Number of trenches 1 Septic Tank Size 1000 Exact length of each trench 225 gallons Trench Spacing: 9 Feet on Center Pump Tank Size _____ Trenches shall be installed on contour at a Soil Cover: 6 gallons Maximum Trench Depth of: 18" - 24" (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. _ inches below pipe inches above pipe Conditions: A 36" deep curtain drain will be required at minimum of 10' upslope of the drainfield WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 12-14-21 Authorized State Agent: _ Construction Authorization Expiration Date: 12-14-21

Harnett County Department of Public Health Site Sketch

Property Location: 95 Dragon Fly Ln (NC 2		
Issued To: Daniel Campbell	Subdivision	Lot #
Authorized State Agent:	M PEHS	Date: 12-14-21
Diright St. 25.	28' Deep Currain Drain 28' Deep Currain Drain Existing Home	
- Dragon Fly In.	>	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.