



Harnett County
420 Mckinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/25/2022

SUBJECT: BRES2112-0003
BUILDING RESIDENTIAL

To: LUETTGER MORGAN ELIZABETH

Here are the results of all Inspections located at **2835 BARBECUE CHURCH RD:**

Inspection Type: FINAL**
Scheduled Date/Time: 3/7/2022
Completed Date/Time: 3/7/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Piers already backfilled. Piers do not appear to be in the locations specified in drawings.

Inspection Type: FINAL**
Scheduled Date/Time: 10/18/2022
Completed Date/Time: 10/18/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Engineer letter attached