

December 30, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Premier Pools and Spas
2140 Page Road Suite 102
Durham, NC 27703

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2112-0004

Ms. M. Yesenia Avila:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other –Disapproved - Primary Disapproval - Septic repair area encroachment- Proposed pool encroached on existing septic repair area (15ft minimum setback). Due to pool location, lot configuration, and available soil, no soil relocated repair area is readily available. Soil scientist proposal required showing located repair area with proposed pool setbacks (15ft min). Provide report for approval.**

Secondary Disapproval- Outlet lid of tank not uncovered and seal not broken free for inspection (required). No proposed pool flagged/marked onsite (required).

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting