

December 30, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Stephanie McKinney
73 Avery Pond Drive
Fuquay-Varina, NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2112-0021

Ms. McKinney:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other –Disapproved-Septic Encroachment-Proposed pool encroaches on 15ft minimum septic/pool setbacks. Septic area flagged onsite. Pool shall be relocated to required setbacks for approval. Site plan revision required.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting