

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Wendy Bryan New Installation Septic Tank
Property Location: SR# off Lafayette Rd Repairs Nitrification Line
Subdivision _____ Lot # _____
TAX ID# _____ Quadrant # _____
Contractor: John Atkins Registration # _____
Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: _____ ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 30 in.
French Drain: _____ Linear feet

PERMIT NO. 09209

Date: 11/17/94
Inspected by: Chris Astew

Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) WENDY BRYAN New Installation Septic Tank
 Property Location: SR# off Lafayette Rd Repairs Nitrification Line
401 N → (R) Lafayette → ~1/2 mi turn (D) where there is a double wide MH with a
 Subdivision single MH behind it → follow path and take (D) Fork → Lot # _____
 Tax ID# Follow PATH → Home on (R) Quadrant # _____
 Number of Bedrooms Proposed: _____ Lot Size: 10AC

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 2 of each ditch 150 ft. ditches 3 ft. ditches 30 in.
 French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 6/18/94
 Signed: Robert H. Zwickler, R.S.
 Environmental Health Specialist

VOID AFTER 5 YEARS

INSTALL ON CONTOUR

