

February 26, 2023

Gene's Backhoe Service Tyler Nordan 1340 Two Claude Rd. Willow Spring, NC 27592

Subject: 61 Rock Ridge Pl, Coats, NC 27521

Mr. Nordan,

At your request, a representative from Wise Engineering (WE) reviewed the existing footing excavations located at 61 Rock Ridge Pl, Coats, NC 27521. Specifically, we reviewed footing excavations for the entire home to provide a third-party inspection prior to concrete placement.

Based on our observations and analysis, the dimensions of the footing excavations were constructed in general compliance of the provided construction documents and the 2018 North Carolina Residential Building Code. Additionally, the soil within the footing excavations is structurally adequate to support the anticipated loading conditions (2000PSF bearing capacity).

If you need additional information or have other questions, please let us know.

Sincerely,

Taylor Poulos

Randy K. Wise, PE