



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

5/9/2022

**SUBJECT: BRES2201-0013**  
**BUILDING RESIDENTIAL**

To: RAMOS JULIET MARIA

Here are the results of all Inspections located at **835 COACHMAN WAY:**

Inspection Type: ELECTRICAL UNDERGROUND  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Slade Burton Lawson III  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Slade Burton Lawson III  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes:

Inspection Type: BONDING  
Scheduled Date/Time: 3/2/2022  
Completed Date/Time: 3/2/2022  
Inspector: Slade Burton Lawson III  
Result: APPROVED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 5/6/2022  
Completed Date/Time: 5/6/2022  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 5/4/2022 2:02 PM Chapman Wilson  
final inspection pool  
Contact Name: Chapman Wilson  
Site Address: 835 COACHMAN WAY  
Phone: 9104244663  
e-Mail: chapwil@aol.com

Inspector SPG changed the inspection assignment from SPG to SBL

Inspector SBL changed the inspection assignment from SBL to SPG

Doors need UL listed alarms. Electrical underground never inspected, expose wiring. Zoning not passed, scheduled for today.

Inspection Type: ZONING  
Scheduled Date/Time: 5/6/2022  
Completed Date/Time: 5/6/2022 10:30 AM  
Inspector: Randy Baker  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 5/4/2022 2:03 PM Chapman Wilson  
doing final also same day  
Contact Name: Chapman Wilson  
Site Address: 835 COACHMAN WAY  
Phone: 9104244663  
e-Mail: chapwil@aol.com

More information is needed as it relates to the flood hazard area.