

January 31, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Jeffrey Johnson
1530 Lafayette Road
Fuquay Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2201-0017

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

3. Replace Sanitary T

4. **Other – Sanitary Tee Replacement Required – Existing concrete sanitary tee leaving septic tank is broken away and out of repair. Replacement required. Replace and reconfirm for return visit and approval.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting