

February 17, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Melony Thompson
PO Box 302
Coats NC 27521

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2201-0027

Ms. Melony:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other – Disapproved- Existing System crosses property line and is sized for a 3-Bedroom DWMH. Property shall be re-combined to state as previously permitted or new septic application filed. Additionally, property lines and building setbacks were not clearly marked. Property corner irons and lines would require locating due to larger DW than previously on lot.**

Applicant met onsite and explained septic area requirements and site plan requirements.

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting