

OPERATIONS PERMIT

Name: (owner) Jennifer Edwards New Installation Septic Tank
Property Location: SR# 1827 Repairs Nitrification Line
Subdivision _____ Lot # _____
TAX ID# _____ Quadrant # _____
Contractor: W+W Builders Registration # _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 2 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 16-18 in.

French Drain: _____ Linear feet

Date: 11-26-97

PERMIT NO. 12644

Inspected by: James E. Markant, E.S.
Environmental Health Specialist



SR 1827

9:45 - 108002

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Jeanette Edwards New Installation Septic Tank
Property Location: SR# 1827 Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 2.57 acre

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 16-19 in. ^{max}


French Drain Required: - Linear feet

Date: 10-22-97

*This permit is subject to revocation if site plans or intended use change.

Signed: James E. Mantel, R.S.
Environmental Health Specialist

* Maintain all setbacks
* Contractor to meet on site prior to installation



* Shallow Line placement
* Shallow Tank placement

SR 1827