Harnett County Department of Public Health Improvement Permit A building permit cannot be issued with only an Improvement Permit

	PROPERTY LOCATION: 71 Georgie Dr (SR 1273)
ISSUED TO: Terry Hinton	LOT #
NEW REPAIR EXPANSION Type of Structure: 76' x 41' SFD	Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: pump to 25% reduction	
Projected Daily Flow: 360 GPD	
Number of bedrooms: 3 Number of Occupants: 6	_max
Basement ☐Yes ☒ No Pump Required: ☒Yes ☐ No ☐ May be required based on final	lession and elevations of facilities
	nce from wellfeet Permit valid for: 🔀 Five years
Permit conditions:	No expiration
A.	
Authorized State Agent:: Mah AEHS	Date: 03-03-22 SEE ATTACHED SITE SKETCH
	er permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	t Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the tams and notes for semage recentlent and orsposal and to conditions of this perinte.	
Consti	ruction Authorization
1	equired for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957	7. 1958. and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.	
ISSUED TO: Terry Hinton	PROPERTY LOCATION: 71 Georgie Dr (SR 1273)
701 441 055	SUBDIVISIONLOT #
Facility Type: 76' x 41' SFD New	Expansion Repair
Basement? Yes No Basement Fixtures? Yes	⊠ No
Type of Wastewater System** pump to 25% reduction	(Initial) Wastewater Flow: 360 GPD
(See note below, if applicable) pump to 25% reduction	n (Repair)
Installation Requirements/Conditions Number of trend	
	each trench 225feet
	pe installed on contour at a Soil Cover: 6inches
	h Depth of: 18" - 20" inches (Maximum soil cover shall not exceed
	shall be level to +/-1/4" 36" above the trench bottom)
in all directions	
Pump Requirements:ft. TDH vsGPM	inches below pipe
	Aggregate Depth:inches above pipe
Conditions:	inches total
WATER LINES (WELLING INDICATION) WHET DE JOET FROM	THIS DADT OF CERTIC CUCTEM OR DEDAID ADDA
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM A	
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD ARE	:A.
**If applicable: 1 understand the system type specified is different from	the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature:	Date:
Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use	Date: changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
	changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use Construction Authorization is subject to compliance with the provisions of the Laws and Rules for	changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Authorized State Agent:	changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Harnett County Department of Public Health Site Sketch

Issued To: Terry Hinto	on	Subdivision	Lot #
Authorized State Age	1//	- REH	Date: 03-03-22
Currain Drain W Of antire Drain	oill be required on Field	10' upslops	
E		Tij	
	110	UCTION)	
	Curtain Drain	76'x41' 3	
TSI	10° 1 1 1 1 1 1 1 1 1	ac-10	~75

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.