

Harnett County 420 Mckinney Pkwy

LILLINGTON,NC 27546 Phone: Fax:

4/11/2023

SUBJECT: BRES2202-0012 BUILDING RESIDENTIAL

To: LAMCO CUSTOM BUILDERS LLC

Here are the results of all Inspections located at 35 SOUTHERN PL:

Inspection Type: FOOTING Scheduled Date/Time: Completed Date/Time: Inspector: Slade Burton Lawson III Result: Remarks: Notes:

Inspection Type:	FOUNDATION
Scheduled Date/Time:	
Completed Date/Time:	
Inspector:	Slade Burton Lawson III
Result:	
Remarks:	
Notes:	

Inspection Type:	MONO SLAB
Scheduled Date/Time:	
Completed Date/Time:	
Inspector:	Slade Burton Lawson III
Result:	
Remarks:	
Notes:	

Inspection Type:	OPEN FLOOR
Scheduled Date/Time:	
Completed Date/Time:	
Inspector:	Slade Burton Lawson III
Result:	
Remarks:	
Notes:	





Harnett County 420 Mckinney Pkwy

LILLINGTON,NC 27546 Phone: Fax:

Inspection Type: SLAB Scheduled Date/Time: Completed Date/Time: Inspector: Slade Burton Lawson III Result: Remarks: Notes:

Inspection Type:UNDER SLAB TRADESScheduled Date/Time:Completed Date/Time:Inspector:Slade Burton Lawson IIIResult:Remarks:Notes:

Inspection Type:	ROUGH IN
Scheduled Date/Time:	11/9/2022
Completed Date/Time:	11/9/2022
Inspector:	James T Hall
Result:	APPROVED
Remarks:	eTRAKiT Inspection Request
Notes:	11/8/2022 2:29 PM LAMCO CUSTOM BUILDERS LLC

Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 35 SOUTHERN PL Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com

INSULATION
11/9/2022
11/9/2022
James T Hall
APPROVED
eTRAKiT Inspection Request
11/8/2022 2:29 PM LAMCO CUSTOM BUILDERS LLC
Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 35 SOUTHERN PL Phone: 9198594190

e-Mail: Lamcoacctdept@gmail.com





		kinney Pkwy
Harnett county North Carolina	LILLING Phone: Fax:	TON,NC 27546
Inspection Type: Scheduled Date/Time: Completed Date/Time: Inspector: Result: Remarks:		FINAL** 3/23/2023 3/23/2023 James T Hall DISAPPROVED eTRAKIT Inspection Request
Notes:		3/17/2023 12:56 PM LAMCO CUSTOM BUILDERS LLC Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 35 SOUTHERN PL Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com
		1.Handrail at front steps2.Lights hanging down in garage3.Need to mud and tape joints in garage ceiling4.Missing energy certificate5.Caulk all countertops and backsplash6.Missing insulation and weatherstripping attached to attic access door7.Missing anti siphon device on back hose bib
Inspection Type Scheduled Date, Completed Date Inspector: Result: Remarks: Notes:	/Time:	FINAL** 4/10/2023 4/10/2023 John B Kokoszka APPROVED eTRAKIT Inspection Request 4/6/2023 10:34 AM LAMCO CUSTOM BUILDERS LLC
		Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 35 SOUTHERN PL Phone: 9198594190

e-Mail: Lamcoacctdept@gmail.com



. .

. .