

February 28, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

David Perez Garcia
407 S Dixon Avenue
Cary, NC 27511

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Application: BRES2202-0022

Mr. Perez Garcia:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- **Disapproved** – **Applicants paperwork reflects a system expansion for 2-bedrooms to 3-bedrooms. Should applicant proceed, expansion paperwork and fees shall be applied. Existing tank location unable to approve in relation to property line setbacks. Full system relocation shall be required. Should applicant proceed, relocation paperwork and fees shall be applied. Should applicant proceed, paperwork shall be filed showing applicants access and availability to Angier sewer to be repair area exempt.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting