

March 10, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Katrina Littlejohn  
2032 Howson Road  
Raleigh, NC 27603

ph: 910-893-7547  
fax: 910-893-9371

**RE: Existing Tank Application # BRES2202-0055**

Ms. Littlejohn:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

\_\_\_ 2. Have system pumped out

\_\_\_ 3. Replace Sanitary T

**X 4. Other – Disapproved – Proposal is for a 5-Bedroom DWMH on the previous site of a SWMH. Existing tank appeared to operate both existing SWMH and former SWMH. Existing system could not support new home of proposed bedroom/occupancy. Existing system is not in full functional condition. Drain field shows signs of occasional/recent failure. System cannot support any additional flow at this time.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting