

May 9, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Katrina Littlejohn
2032 Howson Road
Raleigh, NC 27603

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2202-0055

Ms. Littlejohn:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Application placed on hold prior to evaluation (refund permissible). Site consideration size, well setbacks, existing MH setbacks, existing septic setbacks, pond setback and proposed MH size are not favorable for easy approval. Applicant requested to provide soil scientist proposal prior to proceeding. Proposal is for a 5-bedroom DWMH on the previous site of a SWMH. Existing tank appeared to operate both existing SWMH and former SWMH. Existing system could not support new home of proposed bedroom/occupancy. Existing system is not in full functional condition. Drain field shows signs of occasional/recent failure. System cannot support any additional flow at this time.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting