HARNETT COUNTY INSPECTIONS DEPARTMENT

3RD PARTY INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

| Project Information: | | | |
|--|---|---------------------|----------------------|
| Residential Single Family Project: X Y N | | Commercial Project: | Y X N |
| Code Enforcement Project No.: | | Permit No.: | |
| Project Name: | KEITH HILLS S/D | Owner: | HUGH SURLES BUILDERS |
| Project Address: | 697 KEITH HILLS DRIVE | Suite No.: | |
| Date Inspected: | 3.3.22 | Contractor Name: | CORY GILBERT |
| Component Inspected: | FOOTING | | |
| Responsible Licensed NC Architect or NC Engineer | | | |
| Name: | JOE E. GODWIN JR. | | |
| Firm Name: | ENOCH ENGINEERS P.A. | | |
| Phone No.: Office | 919.894.7765 | Mobile | |
| Email Address: | GENERAL@ENOCHENGINEERS | .СОМ | |
| Mailing Address: | Address: 1403 HWY-50 SOUTH BENSON, NC 27504 | | |
| APPLICABLE CODE SECTION: 2018-NCRC 2018 NCRC = 2018 NC Ruilding Code: 2018 NCRC = 2018 NC Residential Code | | | |

FOOTING SIZE/DEPTH WITH SOIL BEARING CAPACITY OF 2000 PSF. SOIL BEARING FIELD REPORT AVAILABLE UPON REQUEST FROM ENOCH ENGINEERS.

Describe Element/Component/Type of Inspection: *

*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

3/12/2022

LICENSED ARCHITECT OR ENGINEER

DocuSigned by:

339EA4405059480.

Inspection Department disclaimer: Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or

Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

