

April 22, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Rising Sun Pools
5608 Hillsborough Street
Raleigh NC 27606

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2203-0011
45 Wade Stephenson Road Holly Springs, NC 27540

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other – Disapproved – Septic Encroachment – Painted onsite pool encroaches on minimum septic/pool setbacks (15ft). Unable to approve pool as proposed. Site plan shows pool drainage across existing septic area. Pool shall not discharge into septic area. Additionally, proposed pool located on existing uphill drainage area. Subsequent pool placement would shift drain onto existing septic area. Unable to approve pool where relocated drainage will cross septic field. Property was not designed for pool placement in pre-construction planning.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting