

March 24, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

Jovito Lopez
81 Jay Matthews Lane
Fuquay-Varina, NC 27526

RE: Existing Tank Application # BRES2203-0021

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other –Septic encroachment - Proposed additions encroaches (5ft min setback) on existing septic area. No additional decks/porches approvable in vicinity of septic area.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting

