

Harnett County Department of Public Health

PERMIT #BRES2203-0026

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 3533 Old Stage Rd N (SR 1006)

Name: (owner) Phoenix Properties

SUBDIVISION

LOT #

System Installer: Cardenes

Basement with plumbing: Garage Number of Bedrooms 4


Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: 25% reduction type III(G) EZ Flow Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EZ flow

Septic Tank: 1,000 gallons Pump Tank: _____ gallons

Subsurface No. of ditches 3

width of ditches 3 feet depth of ditches 26 → 20 inches

Drainage Field exact length of each ditch 80 feet

French Drain Required: Linear feet

Authorized State Agent _____

REMS

Date 11/26/25