

March 31, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Jeremy and Jill Biggs  
560 Purfoy Road  
Fuquay-Varina NC 27526

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Improvement Permit Application: BRES2203-0036**

Mr. and Mrs. Biggs:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other – Soil Scientist/Engineer Proposal Required – Pool unapprovable due to lot size, property line locations, existing barns and additions, bedroom count (5 per tax code), parking pad, circle drive, & 50ft minimum well setback. Pool is proposed in only visibly available septic repair area. Additionally, pool appears in close proximity to septic lines/tank. Existing system shall be located onsite and pool setback verified and available septic repair area allocated prior to approval. Additionally, septic outlet end shall be made available for inspection per existing tank procedure. Submit Soil Scientist/Engineer proposal and reconfirm when lot is ready.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy: Central Permitting