

HTE #: BRES2203-0060

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Parrot Bay Pools

Phone #: 910-429-0086

Address: 3011 TOWN CENTER DRIVE SUITE 130 FAYETTEVILLE, NC 28306

Name of Mobile Home Park or S/D: _____

Name of Owner (if different): Genusis Ruiz

Address of Owner (if different): 90 Silverthorn Dr, Sanford (SR 2518)

Property Location (State Road name and #): 90 Silverthorn Dr, Sanford (SR 2518)

Purpose of Inspection: addition of indround pool (16' x 36')
Suitable soil for repair in the front yard

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

4-20-22

Date