

Consulting Engineers & Surveyors 1403 NC Highway 50 S Benson, NC 27504 Phone: (919) 894-7765 general@enochengineers.com

May 13, 2022

Premier Property Group 308 North Main Street Four Oaks, North Carolina 27524

Attention: Brendan Barefoot

RE: Structural Foundation

Subject: 328 East Erwin BLVD

Erwin, NC 28339 Lot 4 and Lot 5

To Whom It May Concern:

Our office has performed a structural evaluation of the subject properties referenced above on April 19, 2022. The installation of the foundation pier support "Minute Man XI2" stabilizing system was found to be acceptable for the over height of the CMU piers installed. All installation must meet the requirements for Minute Man XI2 stabilizing system installation methods for Wind Zone 1, the manufactured home installation methods and the pertinent NC codes. No recommendations for additional foundation support are issued at this time.

If we may be of further assistance, please feel free to call.

Respectfully,

DocuSigned by:

339EA4405059480...

Joe E Godwin Jr., PE
Enoch Engineers, PA

DS

SEAL
28919

JEG Jr. / BH
5/13/2022