

April 29, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

WD Smith Construction LLC
1514 N Main Street
Fuquay-Varina, NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2204-0036

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other – Application reflects request for expansion (bedroom addition). Expansion application shall be filed along with documented proposed bedroom count.**
 - (1) Existing tank shall be located and uncovered for inspection of structure/size/condition.**
 - (2) Existing drain line shall be located for determination of type/size/condition**
 - (3) Right property lines and irons shall be located and marked for new/additions to drain field.**
 - (4) Revise land use application to reflect system expansion and proposed bedroom count.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting