

April 29, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

J David & Cynthia Avrette
1082 Keith Hills Road
Lillington, NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2204-0038

Mr. and Mrs. Avrette:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Additional review required. Wood line is not deep to unsuitable soils. Per phone conversation, advised to clear flagged area and reconfirm for final layout. Site plan revision required. Site plan shall show driveway and parking area along with shifting the house forward 10-15ft to accommodate rear septic area.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting