

HTE #: BRES2204-0049

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Jennifer Latino Phone #: (919) 389-0173

Address: 81 Atkins Village Ct Fuquay Varina, NC

Name of Mobile Home Park or S/D: Atkins Village - Lot 4

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 81 Atkins Village Ct (Atkins Rd. - SR 1410)

Purpose of Inspection: 20'x34' Inground Pool - Revised from relocation (07/06/2022) - Pool setbacks (15ft) verified onsite based on marked location of pool


The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

08/05/2022
Date