

May 9, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

Carolina Creations RDU
3304 Drexel Hill Court
Apex, NC 27539

Re: Existing Tank Application: # BRES2204-0056

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other - Disapproved – Site plan does not include any specific measurements. Pool site plan shall be pinned onsite by measurements. Proposed painted pool encroaches on existing septic tank setback (15ft). Pool shall be relocated and proposed accordingly. Septic tank lids not made accessible for inspection. Lids were covered in mulch. Tank lids shall be made accessible and lids broken free to be opened by hand.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/sl
Copy - Central Permitting