

May 12, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Nick and Megan Salisbury
135 Farrah Shea Way
Angier, NC 27501

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2204-0074

Mr. & Mrs. Salisbury:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T

4. **Other – Existing tank denied as applied. Applicant applied for existing tank. Paperwork reflects either revision or relocation requirements. Pool was not marked onsite nor clearly defined on site plan. Septic system marked onsite by contractor. 15ft minimum setback required (18ft off any existing flags). Revise paperwork accordingly to define pool location or file for septic relocation (w/fees). Homeowner advised to provide private soil consultant layout and proposal if guarantee is requested prior to relocation application filed (if applicable).**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting