

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 5328 REDHILL CHURCH RD. (SN 1703)

ISSUED TO: BRETT + JOAN PEARCE SUBDIVISION _____ LOT # _____

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: 4-BEDROOM 28'X66' DWMH

Proposed Wastewater System Type: 25% REDUCTION SIS.

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: E max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well NA feet

Permit valid for: Five years No expiration

Permit conditions: _____

Authorized State Agent: [Signature] Date: 05/10/2022 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: BRETT & JOAN PEARCE PROPERTY LOCATION: 5328 RED HILL CHURCH RD. (SN 1703)

SUBDIVISION _____ LOT # _____

Facility Type: 4-BE 28'X66' DWMH New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable) 25% REDUCTION SIS. (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 3

Exact length of each trench 115 feet

Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches (Trench bottoms shall be level to +1-1/4" in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: NA inches below pipe

NA inches above pipe

Conditions: GRAVITY TO D-BOX EQUAL DISTRIBUTION REQUIRED

NA inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 05/10/2022

ANDREW CURRAN

Construction Authorization Expiration Date: 05/10/2027

Application # BLES 2204-0078

Harnett County Department of Public Health Site Sketch

Property Location: 5328 RED HILL CHURCH RD. (SL 1703)

Issued To: BRETT + JOAN PERDUE Subdivision _____ Lot # _____


Authorized State Agent: *[Signature]* Date: 05/10/2023

ANDREW CURRIN

* NO PARKING PAD, DECKS, PORCHES, SHEDS, BARN, POOLS, DETACHED STRUCTURES MARKED ON SITE OR ON SITE PLAN

↳ ALL SHALL BE DEPENDENT ON FINAL SEPTIC LOCATION + SETBACKS

* GRAVITY TO D-BOX EQUAL DISTRIBUTION REQUIRED



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.

P.L.