



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/3/2024

SUBJECT: **BRES2205-0021**
BUILDING RESIDENTIAL

To: GARAGE BUILDERS OF RALEIGH

Here are the results of all Inspections located at **340 FIELDSTONE DR:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 6/28/2022
Completed Date/Time: 6/28/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/24/2022 3:37 PM Robert Clade

Contact Name: Robert Clade
Site Address: 340 FIELDSTONE DR
Phone: 9193691507
e-Mail: bob@garagebuildersofraleigh.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 7/20/2022
Completed Date/Time: 7/20/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/16/2022 3:50 PM Robert Clade

Contact Name: Robert Clade
Site Address: 340 FIELDSTONE DR
Phone: 9193691507
e-Mail: bob@garagebuildersofraleigh.com

Inspection Type: SLAB
Scheduled Date/Time: 7/28/2022
Completed Date/Time: 7/28/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 9/12/2022
Completed Date/Time: 9/12/2022
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes:

Will need engineer letter for 2x4 wall stud height per code. The plan drawn does show 2x4 for the wall but the plan does not have the engineers seal on it. Ok to cover exterior.

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 11/7/2022
Completed Date/Time: 11/7/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/2/2022 3:50 PM Robert Clade
engineer letter emailed to central permitting
Contact Name: Robert Clade
Site Address: 340 FIELDSTONE DR
Phone: 9193691507
e-Mail: bob@garagebuildersofraleigh.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: Per engineer letter
~~Scheduled Date/Time:~~
Inspection Type: FINAL**
Scheduled Date/Time: 11/8/2022
Completed Date/Time: 11/8/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/2/2022 3:51 PM Robert Clade
engineer letter emailed to Central Permitting
Contact Name: Robert Clade
Site Address: 340 FIELDSTONE DR
Phone: 9193691507
e-Mail: bob@garagebuildersofraleigh.com