



Permit Inspections Harnett County

Permit Number: BRES2205-0030

Description: 14 x 80

Applied: **5/17/2022**

Approved: **6/2/2022**

Site Address: **145 BLAKE ST**

Issued: **6/3/2022**

Finalized:

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **ISSUED**

Applicant: **Elliott Claudia**

Parent Permit:

Owner: **ACG SOUTHEASTERN WAKE LLC**

Parent Project:

Contractor: **Elliott Claudia**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			MFH FINAL**	Steven Gazlay		
Notes:						
			SEWER CONNECTION	Steven Gazlay		
Notes:						
			WATER CONNECTION	Steven Gazlay		
Notes:						
			ZONING	Planning Bucket		
Notes:						
			MH FOUND/MARRIAGE WALL	Steven Gazlay		
Notes:						
	6/6/2022	6/6/2022	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
Notes: 1. Seal all holes in belly board under house. 2. 6 mill poly under house on ground needs to be pinned in place & cover underneath . 3. Need DWV test on drain line. 4. Water line not connected it needs to be connected under house with cut off valve & pro valve and be insulated per code.						
	7/11/2022	7/11/2022	MH FOUND/MARRIAGE WALL	Scott Guy	DISAPPROVED	
Notes: No water in drain test						





Permit Inspections Harnett County

	8/30/2022	8/30/2022	MH FOUND/MARRIAG E WALL	John B Kokoszka	DISAPPROVED	
Notes:						
Missing pressure reducer valve Need to have dwv water test full to the bottom of the mobile home						
	9/20/2022		ADDRESS	GIS Bucket		
Notes:						

