



CIVIL AND STRUCTURAL ENGINEERING SERVICES, PLLC
SAMIR W. BAHHO, P.E.
Date: August 29, 2022

Rodriguez Residence
181 Rad Street
Lillington, NC 27546

Reference: Foundation Excavation, Rodriguez Residence
Permit # BRES22206-0005
House Foundation Excavation Certification.

I hereby certify the continuous footers on the sides of the existing house as shown on the approved plans are not needed.

As-Built Foundation, piers and footers satisfy load requirement of NCBC, Residential, Edition 2018 of **2,000 lb/SF**. My seal is affixed below for certification.

For any further questions, please call me or email me. My telephone number is (919) 621-0628. My email address is ba.casespllc@gmail.com

Sincerely,

Samir W. Bahho, P. E. (License # 16941-Business License # P-0537)



August, 29, 2022

