



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

11/22/2022

SUBJECT: **BRES2206-0006**
BUILDING RESIDENTIAL

To: JENKINS CHARLES P

Here are the results of all Inspections located at **465 FIELDSTONE DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 7/6/2022
Completed Date/Time: 7/6/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 8/19/2022
Completed Date/Time: 8/19/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time: 9/16/2022
Completed Date/Time: 9/16/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 11/22/2022
Completed Date/Time: 11/22/2022
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:

Notes: 1. Floor truss above stair landing that has two trusses hangered to it needs a hanger on each side. 2. The last rafter at rear left missing hurricane clip. Ok to insulate