



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/12/2022

SUBJECT: BRES2206-0009
BUILDING RESIDENTIAL

To: PHILLIPS SHERYL A

Here are the results of all Inspections located at **347 FOREST DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 9/2/2022
Completed Date/Time: 9/2/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Discussed with contractor. Provide code complaint footings. Cannot bolt deck to mfh brick skirting.





Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 9/7/2022
Completed Date/Time: 9/7/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: