

OPERATIONS PERMIT

Name: (owner) Showcase Court New Installation Septic Tank
Property Location: SR# 1115 Repairs Nitrification Line
Subdivision Peach Tree Crossing Lot # 6
TAX ID# _____ Quadrant # _____
Contractor: Carter Brothers Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other Polystyrene Aggregate Trach System TAWS-95-3R

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 1 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain: _____ Linear feet

Date: 12/15/88

PERMIT NO. 15179

Inspected by: Bruce McFuer R.S.
Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Showcase Const. Co.

New Installation Septic Tank

Property Location: SR# off 1115 Buffalo Lake Rd.

Repairs Nitrification Line

Subdivision Peachtree Crossing Lot # 6

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Polystyrene Aggregate Trench System F.W.S. 95-312

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: _____ Linear feet

Date: 12/8/98

This permit is subject to revocation if site plans or intended use change.

Signed: Bryan McSwain P.E.
Environmental Health Specialist

* Maintain all required setbacks

