

July 7, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Virginia Smith
676 Raiford Road
Erwin NC 28339

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2206-0045

Ms. Smith:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Unable to inspect tank. Appears only inlet end of tank uncovered and open. Tank grown over with vegetation growing out of tank. Tank shall be fully exposed on both ends and made visible for inspection for approval. Coordinate with a septic contractor/pumper for inspection.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting