

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

July 21, 2022

Magdalena Mortera
461 Cypress creek farm Rd
Sanford, NC 27532

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application #BRES2207-0002

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal on lid. (\$25.00 fee incurred)**
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – revise site plan to meet the 5 foot setback from the drain lines**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting