

July 20, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Hasker Yon III
282 Regal Crest Drive
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2207-0009

Mr. Yon:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic Encroachment – Existing top septic line passes through corner of proposed garage. Line marked onsite. Garage shall be shifted 10ft uphill minimum to meet minimum setback. Remark building onsite and revise Site plan accordingly. Reconfirm when ready.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting