

July 18, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Billy Griggs  
301 11<sup>th</sup> Street  
Butner NC 27501

ph: 910-893-7547  
fax: 910-893-9371

**Re: Existing Tank Application: # BRES2207-0011**

Mr. Griggs:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

\_\_\_ 2. Have system pumped out

\_\_\_ 3. Replace Sanitary T

**X 4. Other – Disapproval – Septic Encroachment – Proposed deck encroaches upon existing septic field (see Operational Permit). Closest line to proposed deck marked onsite and located via ground radar. Proposed deck shall be revised to meet 5ft minimum septic setbacks (6.5ft from flags since marked at center). Revise site plan with any foundation pillar greater than 6.5ft minimum from field and mark structure out accordingly onsite. Reconfirm when ready for revised approval.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting