



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

9/30/2022

SUBJECT: BRES2207-0018
BUILDING RESIDENTIAL

To: Autry Danny

Here are the results of all Inspections located at **155 BLUE PINE DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 8/1/2022
Completed Date/Time: 8/1/2022
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: Scheduled by Jeff Autry

Footing had water in it. The bottom of the footing need to be at frost level 12' below grade. Pipe sleeve need to be 2 sizes bigger and Annular space need to be filled. Cannot use corrugated pipe





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 8/4/2022
Completed Date/Time: 8/4/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 8/2/2022 10:39 AM Danny Autry Sr

Contact Name: Danny Autry Sr
Site Address: 155 BLUE PINE DR
Phone: 9192621867
e-Mail: danny.autry@yahoo.com

Inspector JTH changed the inspection assignment from JTH to SPG
Footing must be continuous across garage door opening. Dowel into existing footing.

Inspection Type: FOOTING
Scheduled Date/Time: 8/5/2022
Completed Date/Time: 8/5/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 9/7/2022
Completed Date/Time: 9/7/2022
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes: Please call Rose Ferguson (owner) before going out at (910)578-3688.