

APPENDIX G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: (Y) N	Commercial Project: Y N
Code Enforcement Project No:	Permit No:
Project Name: RYAN TROYER	Owner:
Project Address: 65 SANATRA DRIVE, CAMERON, N.C. 28326	Suite No:
Date Inspected: 5/28/26	Contractor Name:
Component Inspected: FOOTERS	

Responsible Licensed NC Architect or NC Engineer

Name:	MICHAEL CAVNAR
Firm Name:	COMPLETE ENGINEERING & CONSULTING, PLLC
Phone Numbers:	Office: 1-910-499-6703 Mobile: 1-910-476-6039
Email Address:	MCVNAR@EARTHINK.NET
Mailing Address:	4721 RAY ROAD, SPRING LAKE, N.C. 28390

APPLICABLE CODE:

2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: * PERIMETER FOOTERS 16" INCHES


WIDE, 8" THICK, 3000 PSI CONCRETE WAS USED. THE PIER FOOTERS 24X24" X 12" THICK, 3000 PSI CONCRETE WAS USED, THIS WAS SPOT CHECKED BY THE ENGINEER ON SITE.

*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.

Michael Cavnar 6/1/26
Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.