

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

June 7, 2024

Subject: 2021 Clayhole Road  
Coats, NC 27521  
Framing Inspection Letter

Based on the request of the Contractor, I looked at 1 item in the mobile home for code compliance. My assessment and recommendations are as follows:

- The Contractor installed a new double 2x8 header with 2 jack studs under each end for a new 8' wide window. The new header supports the roof members of the mobile home. The new 2x8 header is acceptable.

The new header meets all the requirements of the 2018 North Carolina Building Code for Residences.



# Signature Certificate



Envelope Ref:81339fcfeb5d45f1e8cafcc10c9cdc77ba68feeb

Author: Joel S. Howerton    Creation Date: 07 Jun 2024, 08:23:33, EDT    Completion Date: 07 Jun 2024, 08:23:57, EDT

## Document Details:



Name: 2021 Clayhole Road Framing Inspection Letter

Type:

Document Ref: 08474d35996193717a97182dcf019a80b19ce102619d0ee417422ae2e2b53f72

Document Total Pages: 1

## Document Signed By:

Name: Joel S. Howerton  
Email: joeltarheel66@yahoo.com  
IP: 2603:6080:a309:5223:e178:d16b:d868:1e52  
Location: HILTON HEAD ISLAND, SC (US)  
Date: 07 Jun 2024, 08:23:57, EDT  
Consent: eSignature Consent Accepted  
Security Level: Email

## Document History:

Envelope Created: Joel S. Howerton created this envelope on 07 Jun 2024, 08:23:33, EDT  
Signed by Joel S. Howerton: Joel S. Howerton signed this Envelope on 07 Jun 2024, 08:23:57, EDT  
Executed: Document(s) successfully executed on 07 Jun 2024, 08:23:57, EDT  
Signed Document(s): Link emailed to joeltarheel66@yahoo.com