

August 3, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Kristy Stocks
2585 Sheriff Johnson Road
Lillington NC 27546

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2207-0059

Mrs. Stocks:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

____ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

____ 2. Have system pumped out

____ 3. Replace Sanitary T

4. **Other – Disapproved as applied. Septic Encroachment. Proposed pool appears to encroach on existing septic supply line. Proposed pool shall meet 15ft septic tank and drain field setbacks and 10ft supply line setback. Applicant's options are as follows:**

- (1) Move Proposed Pool uphill to meet setbacks (revision)**
- (2) Move septic supply line to meet setbacks (coordinate with EH staff)**
- (3) Apply for tank relocation with applicable fees (revision)**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting