

August 1, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

MEM Carpentry LLC
1145 Oakridge River Road
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2207-0061

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

_____ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

_____ 2. Have system pumped out

_____ 3. Replace Sanitary T

4. Other – Disapproved - Septic Encroachment – Proposed deck appears to encroach on existing septic field location. Septic field highest line flagged onsite (red). Deck foundation appears to not need 5ft septic setbacks. Deck shall be pushed closer (smaller) to the home for approval. Pool must be 6.5ft from flagged septic area (5ft setback + 1.5ft to edge of ditch). Revise paperwork accordingly. Lot lacks available space to relocate septic field and still have available repair field area. Private soil scientist consultation and proposal required of septic area and repair area to relocate septic field.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting