

August 5, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Jose/Feliciano Avilez
5859 Christian Light Road
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2207-0067

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T

4. Other –Disapproved – Existing tank denied. Application reflects request for bedroom additions. Existing septic system approved in 2018 is only sized for 2-bedrooms Max. Front yard lacks available space for septic expansion and equivalent repair area. Proposal disapproved unless county provided with soil consultant layout and proposals.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting