

August 5, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Vuncannon & Sons Builders, Inc
112 Strickland Lane
Lillington NC 27546

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application: # BRES2207-0072

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T

4. Other –Septic Encroachment – Septic field cross off back of existing porch as consistent with existing operational permit. Field marked onsite via flags. Proposed additions unapprovable based on existing septic field location. Any septic relocation and expansion application would likely require a private soil consultant proposal.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns, please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting